



**Henry County
Purchasing Department**
140 Henry Parkway, McDonough, GA 30253
Phone: 770-288-6027 Fax: 770-288-6047

Website: henrycounty-ga.com/purchasing

ADDENDUM #1
Issued June 23, 2020

Bid # 20-48
Widening of West Village Parkway/Panola Road
Due Date and Time: June 30, 3:00 PM

The following items take precedence over referenced portions of the documents for the above-named project and in executing a contract, will become a part thereof. Where any item in the documents is supplemented hereby, the original requirements will remain in effect. All supplemental conditions will be considered as added thereto. Where any original item is amended, voided or superseded hereby, the provisions of such items not so specifically amended, voided or superseded will remain in effect.

REVISION:

The Bid Price Sheets have been revised and are included in this addendum.

This addendum must be signed and attached to bid proposal to acknowledge receipt of addendum.
Failure to acknowledge any addenda will result in a non-responsive bid.

Company's Name

Date

Authorized Representative's Name

Authorized Representative's Signature

Bid # 20-48
Widening of West Village Parkway/Panola Road
Questions and Answers

- 1. Question:** On plan sheet 06-0003 you have a quantity block for Field Engineer Office Type 3 – 1 Each however we did not see a bid item for this. Could you please add a bid item for this as well as provide a Special Provision as to what you would like the Field Office to consist of?
Answer: **Field Engineer Office will not be used on this project.**
- 2. Question:** How do you intend to pay for the Anti-Seep Collars for the Ponds?
Answer: **Anti-seep collars should be included with overall bid price for reinforced concrete pipe. See note 2 regarding anti-seep collars on drawing no. 38-0004.**
- 3. Question:** How do you intend to pay for the Dry Detention Basin 222+51 RT Access Road materials, which appears to be 4 inches of Aggregate Surface Course placed on Filter Fabric? Will it be paid as Aggre Surface Crs-By the Ton since you have a bid item established for Aggr Surface Crs?
Answer: **As noted on drawing no. 18-0001 and drawing no. 18-0002, all items and materials necessary for final construction of detention basin items shall be included in overall bid price for dry detention basin.**
- 4. Question:** Since you have a bid item for Plastic Filter Fabric, it would seem logical to pay for the Filter Fabric under the Dry Detention Basin 222+51 RT Access Road utilizing this bid item, Will that be your intent for this project?
Answer: **As noted on drawing no. 18-0001 and drawing no. 18-0002, all items and materials necessary for final construction of detention basin items shall be included in overall bid price for dry detention basin.**
- 5. Question:** Could you please provide a Special Provision and Construction Detail for the Impermeable Geomembrane Liner that you want installed within the fill slopes Dam for each of the Dry Detention Basins? Also, how do you intend to pay for this Impermeable Geomembrane?
Answer: **Please see 1.12 Wet Pond Material Specifications. Contractors may need to call around to clarify from suppliers.**
- 6. Question:** Could you please provide a complete list of items/work scope that you consider to be incidental to the Cost and Construction of each of the Dry Detention Basins?
Answer: **As noted on drawing no. 18-0001 and drawing no. 18-0002, all items and materials necessary for final construction of detention basin items shall be included in overall bid price for dry detention basin. Details provided on 38 sheets are sufficient for identifying and quantifying materials necessary to complete construct as proposed in plans.**
- 7. Question:** Should we assume that you want to use a Concrete Collar to join the Storm Drain Pipe to the 10' x 8' Double Box Culvert at C1 and E0?
Answer: **Detail is provided on drawing no. 05-011.**
- 8. Question:** In the Summary Of Quantities (Sheet 06-0005) you list Drainage Structure P1-P2 for Pond H as being 50 LF of 18" RCP, however plan sheet 13-0016 and 18-0002 both show P1-P2 as being 24" RCP. Are we to assume that the Plan Sheets are correct and that the Summary of Quantities sheet is not correct? Please clarify what you want for P1-P2.
Answer: **The plan sheets are correct. 24" RCP should be used for the outlet pipe on Pond H (P1-P2). A quantity amendment shall be provided.**

9. **Question:** Can you please confirm that it is your intent to Pay for the Storm Drain Pipe (by the LF) for both Pond G & H using the respective Storm Drain Pipe bid items and that Storm Drain Lines 01-02 and P1-P2 are not incidental to the costs of the Dry Detention Basins?
Answer: **Outlet pipes for the ponds shall be paid for as linear foot of storm drain pipe as listed in the quantity sheets.**
10. **Question:** Is it your intent to Construct the Dry Detention Basins as shown in the 18 & 38 Series Plan Sheet first and use them as Temporary Sediment Ponds during construction, then clean them out and add the Dry Detention Basin features to them? Will there be any Temporary Features that will need to be installed while they are Temporary Sediment Basins?
Answer: **Yes, the intent is to construct first and use as temporary sediment ponds. As shown on the 54-series plans, a retrofit and filter ring should be constructed around the outlet control structure during ponds use as temporary sediment basin.**
11. **Question:** Will there be any Special Soils, Filter Media and or Plantings that will be need to be included in the Dry Detention Basins or is everything you want detailed out on the 18 and 38 Series Plan Sheets?
Answer: **No.**
12. **Question:** On plan sheet 06-0003 you show a total quantity of 356 Tons of Asphalt Leveling required for West Village Pkwy, Peachtree Glenn Drive and Old West Panola Rd, then you added 2,500 Tons of “As Directed Leveling” and then that total (2,988 Tons) was inflated again to get a bid item quantity of 3,100 Tons. Why is the bid quantity 10 Times more than what is really needed, especially given the fact that most of the Road is being reconstructed brand new? This super inflated bid quantity just causes the bids to artificially higher than need be. Would you please reconsider the bid quantity to something more like 500 Tons?
Answer: **3,100 Tons of Asphalt Leveling will remain on the bid quantity.**
13. **Question:** We have a question regarding the maintenance of the existing traffic signal installation. Due to the very limited signalization scope (2 ea. – 6’x40’ loop detectors, adjust pull box to grade) and the 720 calendar day duration of the project, it is impossible to quantify a realistic cost to maintain the existing signal. Would the County consider reducing the time for maintenance to begin when the signalization scope begins and end after a thirty day burn is completed?
Answer: **The contractor shall be responsible for the maintenance of the existing traffic signal during the contract duration of the project.**
14. **Question:** Where is the 10300’ of conduit located in the plans?
Answer: **This quantity is to install conduit for street lights through the project. The location will be provided at a later date.**
15. **Question:** What are the allowable working hours?
Answer: **There shall be no work between 6 am to 9 am Monday through Friday.**
16. **Question:** Who will handle the material testing? Will the County hire a testing firm?
Answer: **All the material testing will be performed by the County. Henry County will use a private Geotechnical firm for all material testing.**
17. **Question:** Will the GDOT AC Index Spec apply to this project since it is a 720 calendar day completion date?
Answer: **No.**

18. **Question:** The summary of quantities are broken into Clayton County vs Henry County. Will they all be paid for under one bid item?
Answer: It will be paid under one bid item.
19. **Question:** What all is to be included in the dry detention basin pay items? Are there any temporary conditions needed for these basins? If so, how will it be paid for?
Answer: All materials needed for construction of dry detention basins should be included in overall bid price for dry detention basin. The basins should be used as sediment basins during construction and all pay items required are shown on drawing no. 06-0007.
20. **Question:** Will any temp barrier be needed? If so, can a pay item be added?
Answer: Temporary barrier will not be needed on this project.
21. **Question:** There is pay item 682-6233, Conduit Type 3, 2", 10,300 LF. I cannot find this conduit on any sheets. Please advise where this is located.
Answer: Please see question #14.

Bid # 20-48
Widening of West Village Parkway/Panola Road
Bid Price Sheet (Revised)

LINE NO.	ITEM NO.	ITEM DESCRIPTION ROADWAY	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0005	150-1000	TRAFFIC CONTROL - SP 4512	LS	1		
0010	169-0015	DRY DETENTION BASIN, NO. - 1, STA 213+20 LT	EA	1		
0015	169-0015	DRY DETENTION BASIN, NO. - 2, STA 222+51 RT	EA	1		
0020	207-0203	FOUND BKFILL MATL, TP II	CY	95		
0025	210-0100	GRADING COMPLETE - SP 4512	LS	1		
0030	310-1101	GR AGGR BASE CRS, INCL MATL	TN	27659		
0035	318-3000	AGGR SURF CRS	TN	600		
0040	402-1812	RECYCLED ASPH CONC LEVELING, INCL BITUM MATL & H LIME	TN	3100		
0045	402-3121	RECYCLED ASPH CONC 25 MM SUPERPAVE, GP 1 OR 2, INCL BITUM MATL & H LIME	TN	7087		
0050	402-3130	RECYCLED ASPH CONC 12.5 MM SUPERPAVE, GP 2 ONLY, INCL BITUM MATL & H LIME	TN	3206		
0055	402-3190	RECYCLED ASPH CONC 19 MM SUPERPAVE, GP 1 OR 2, INCL BITUM MATL & H LIME	TN	3571		
0060	413-0750	TACK COAT	GL	3503		
0065	432-5010	MILL ASPH CONC PVMT, VARIABLE DEPTH	SY	5203		
0070	441-0016	DRIVEWAY CONCRETE, 6 IN TK	SY	919		
0075	441-0104	CONC SIDEWALK, 4 IN	SY	8669		
0080	441-0108	CONC SIDEWALK, 8 IN	SY	76		
0085	441-0740	CONCRETE MEDIAN, 4 IN	SY	907		
0090	441-0754	CONCRETE MEDIAN, 7 1/2 IN	SY	234		
0095	441-4020	CONC VALLEY GUTTER, 6 IN	SY	607		
0100	441-4030	CONC VALLEY GUTTER, 8 IN	SY	62		
0105	441-5004	CONCRETE HEADER CURB, 10 IN, TP 4	LF	82		
0110	441-6222	CONC CURB & GUTTER, 8 IN X 30 IN, TP 2	LF	12038		
0115	441-6740	CONC CURB & GUTTER, 8 IN X 30 IN, TP 7	LF	9262		
0120	446-1100	PVMT REINF FABRIC STRIPS, TP 2, 18 INCH WIDTH	LF	5650		
0125	500-3002	CLASS AA CONCRETE	CY	347		
0130	500-3110	CLASS A CONCRETE, TYPE P1, RETAINING WALL	LF	223		
0135	500-3800	CLASS A CONCRETE, INCL REINF STEEL	CY	14		

Company's Name: _____

Bid # 20-48
Widening of West Village Parkway/Panola Road
Bid Price Sheet (Revised)

LINE NO.	ITEM NO.	ITEM DESCRIPTION ROADWAY (CONTINUED)	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0140	500-9999	CLASS B CONC, BASE OR PVMT WIDENING	CY	23		
0145	511-1000	BAR REINF STEEL	LB	32599		
0150	550-1180	STORM DRAIN PIPE, 18 IN, H 1-10	LF	6038		
0155	550-1240	STORM DRAIN PIPE, 24 IN, H 1-10	LF	1748		
0160	550-1300	STORM DRAIN PIPE, 30 IN, H 1-10	LF	305		
0165	550-1360	STORM DRAIN PIPE, 36 IN, H 1-10	LF	19		
0170	550-1420	STORM DRAIN PIPE, 42 IN, H 1-10	LF	401		
0175	550-2180	SIDE DRAIN PIPE, 18 IN, H 1-10	LF	122		
0180	550-3318	SAFETY END SECTION 18 IN, STORM DRAIN, 4:1 SLOPE	EA	1		
0185	550-4118	FLARED END SECTION 18 IN, SIDE DRAIN	EA	6		
0190	550-4218	FLARED END SECTION 18 IN, STORM DRAIN	EA	12		
0195	550-4224	FLARED END SECTION 24 IN, STORM DRAIN	EA	1		
0200	550-4230	FLARED END SECTION 30 IN, STORM DRAIN	EA	2		
0205	550-4236	FLARED END SECTION 36 IN, STORM DRAIN	EA	1		
0210	550-4242	FLARED END SECTION 42 IN, STORM DRAIN	EA	1		
0215	607-1000	MORTAR RUBBLE MASONRY	CY	36		
0220	611-3000	RECONSTR CATCH BASIN, GROUP 1	EA	3		
0225	611-8050	ADJUST MANHOLE TO GRADE	EA	3		
0230	634-1200	RIGHT OF WAY MARKERS	EA	100		
0235	641-1100	GUARDRAIL, TP T	LF	21		
0240	641-1200	GUARDRAIL, TP W	LF	1339		
0245	641-5001	GUARDRAIL ANCHORAGE, TP 1	EA	1		
0250	641-5015	GUARDRAIL TERMINAL, TP 12A, 31 IN, TANGENT, ENERGY-ABSORBING	EA	2		
0255	643-1152	CH LK FENCE, ZC COAT, 6 FT, 9 GA	LF	1201		
0260	643-8010	GATE, CHAIN LINK ZC COAT -	EA	2		
0265	643-8200	BARRIER FENCE (ORANGE), 4 FT	LF	903		
0270	668-1100	CATCH BASIN, GP 1	EA	69		

Company's Name: _____

Bid # 20-48
Widening of West Village Parkway/Panola Road
Bid Price Sheet (Revised)

LINE NO.	ITEM NO.	ITEM DESCRIPTION ROADWAY (CONTINUED)	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0275	668-1110	CATCH BASIN, GP 1, ADDL DEPTH	LF	37		
0280	668-1200	CATCH BASIN, GP 2	EA	2		
0285	668-1210	CATCH BASIN, GP 2, ADDL DEPTH	LF	7		
0290	668-2100	DROP INLET, GP 1	EA	4		
0295	668-2110	DROP INLET, GP 1, ADDL DEPTH	LF	1		
0300	668-4300	STORM SEWER MANHOLE, TP 1	EA	9		
0305	668-4311	STORM SEWER MANHOLE, TP 1, ADDL DEPTH, CL 1	LF	11		
0310	668-4312	STORM SEWER MANHOLE, TP 1, ADDL DEPTH, CL 2	LF	10		

SUBTOTAL (ROADWAY)

LINE NO.	ITEM NO.	ITEM DESCRIPTION TEMPORARY EROSION CONTROL	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0315	163-0232	TEMPORARY GRASSING	AC	33		
0320	163-0240	MULCH	TN	414		
0325	163-0300	CONSTRUCTION EXIT	EA	4		
0330	163-0503	CONSTRUCT AND REMOVE SILT CONTROL GATE, TP 3	EA	13		
0335	163-0527	CONSTRUCT AND REMOVE RIP RAP CHECK DAMS, STONE PLAIN RIP RAP/SAND BAGS	EA	69		
0340	163-0540	CONSTRUCT AND REMOVE RETROFIT, STA NO - 213+20	EA	1		
0345	163-0540	CONSTRUCT AND REMOVE RETROFIT, STA NO - 222+51	EA	1		
0350	163-0541	CONSTRUCT AND REMOVE ROCK FILTER DAMS	EA	1		
0355	163-0542	CONSTRUCT AND REMOVE STONE FILTER RING	EA	2		
0360	163-0550	CONSTRUCT AND REMOVE INLET SEDIMENT TRAP	EA	84		
0365	165-0010	MAINTENANCE OF TEMPORARY SILT FENCE, TP A	LF	4759		
0370	165-0030	MAINTENANCE OF TEMPORARY SILT FENCE, TP C	LF	2690		
0375	165-0041	MAINTENANCE OF CHECK DAMS - ALL TYPES	LF	963		
0380	165-0060	MAINTENANCE OF TEMPORARY SEDIMENT BASIN, STA NO - 213+20	EA	1		
0385	165-0060	MAINTENANCE OF TEMPORARY SEDIMENT BASIN, STA NO - 222+51	EA	1		
0390	165-0087	MAINTENANCE OF SILT CONTROL GATE, TP 3	EA	13		
0395	165-0095	MAINTENANCE OF RETROFIT, STA NO - 213+20	EA	1		

Company's Name: _____

Bid # 20-48
Widening of West Village Parkway/Panola Road
Bid Price Sheet (Revised)

LINE NO.	ITEM NO.	ITEM DESCRIPTION TEMPORARY EROSION CONTROL (CONTINUED)	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0400	165-0095	MAINTENANCE OF RETROFIT, STA NO - 222+51	EA	1		
0405	165-0101	MAINTENANCE OF CONSTRUCTION EXIT	EA	4		
0410	165-0105	MAINTENANCE OF INLET SEDIMENT TRAP	EA	84		
0415	165-0110	MAINTENANCE OF ROCK FILTER DAM	EA	1		
0420	165-0111	MAINTENANCE OF STONE FILTER RING	EA	2		
0425	167-1000	WATER QUALITY MONITORING AND SAMPLING	EA	4		
0430	167-1500	WATER QUALITY INSPECTIONS	MO	24		
0435	171-0010	TEMPORARY SILT FENCE, TYPE A	LF	4759		
0440	171-0030	TEMPORARY SILT FENCE, TYPE C	LF	2690		
SUBTOTAL (TEMPORARY EROSION CONTROL)						
LINE NO.	ITEM NO.	ITEM DESCRIPTION PERMANENT EROSION CONTROL	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0445	603-2181	STN DUMPED RIP RAP, TP 3, 18 IN	SY	200		
0450	603-2182	STN DUMPED RIP RAP, TP 3, 24 IN	SY	187		
0455	603-7000	PLASTIC FILTER FABRIC	SY	387		
0460	700-6910	PERMANENT GRASSING	AC	16		
0465	700-7000	AGRICULTURAL LIME	TN	101		
0470	700-8000	FERTILIZER MIXED GRADE	TN	13		
0475	700-8100	FERTILIZER NITROGEN CONTENT	LB	847		
0480	700-9300	SOD	SY	4491		
0485	711-0100	TURF REINFORCING MATTING, TP 1	SY	805		
0490	716-2000	EROSION CONTROL MATS, SLOPES	SY	3926		
SUBTOTAL (PERMANENT EROSION CONTROL)						
LINE NO.	ITEM NO.	ITEM DESCRIPTION SIGNING & MARKING	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0495	636-1033	HIGHWAY SIGNS, TP 1 MATL, REFL SHEETING, TP 9	SF	76		
0500	636-1036	HIGHWAY SIGNS, TP 1 MATL, REFL SHEETING, TP 11	SF	187		
0505	636-2070	GALV STEEL POSTS, TP 7	LF	525		
0510	636-2090	GALV STEEL POSTS, TP 9	LF	29		

Company's Name: _____

Bid # 20-48
Widening of West Village Parkway/Panola Road
Bid Price Sheet

LINE NO.	ITEM NO.	ITEM DESCRIPTION SIGNING & MARKING (CONTINUED)	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0515	653-0120	THERMOPLASTIC PVMT MARKING, ARROW, TP 2	EA	25		
0520	653-0170	THERMOPLASTIC PVMT MARKING, ARROW, TP 7	EA	8		
0525	653-1501	THERMOPLASTIC SOLID TRAF STRIPE, 5 IN, WHITE	LF	15965		
0530	653-1502	THERMOPLASTIC SOLID TRAF STRIPE, 5 IN, YELLOW	LF	12432		
0535	653-1704	THERMOPLASTIC SOLID TRAF STRIPE, 24 IN, WHITE	LF	90		
0540	653-1804	THERMOPLASTIC SOLID TRAF STRIPE, 8 IN, WHITE	LF	823		
0545	653-3501	THERMOPLASTIC SKIP TRAF STRIPE, 5 IN, WHITE	GLF	13508		
0550	653-6500	IMPRESSED THERMOPLASTIC HERRINGBONE PATTERN	SY	79		
0555	653-6006	THERMOPLASTIC TRAF STRIPING, YELLOW	SY	63		
0560	654-1001	RAISED PVMT MARKERS TP 1	EA	26		
0565	654-1003	RAISED PVMT MARKERS TP 3	EA	413		
0570	682-6233	CONDUIT, NONMETL TP 3, 2 IN	LF	10300		
SUBTOTAL (SIGNING AND MARKING)						
LINE NO.	ITEM NO.	ITEM DESCRIPTION TRAFFIC SIGNAL ITEMS	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0575	647-1000	TRAFFIC SIGNAL INSTALLATION NO - 1	LS	1		
LINE NO.	ITEM NO.	ITEM DESCRIPTION LANDSCAPING	UNITS	QTY.	UNIT PRICE	EXTENDED PRICE
0580	702-0051	AMELANCHIER X GRANDIFLORA - 5 GAL	EA	70		
0585	702-0212	CRATAEGUS VIRIDIS - 3 GAL	EA	137		
0590	702-0358	ILEX CORNUTA - 3 GAL	EA	408		
0595	702-0470	ILEX VOMITORIA NANA - 3 GAL	EA	1249		
0600	702-0678	MULLENBERGIA CAPILLARIS- 3 GAL	EA	124		
0605	702-9025	LANDSCAPE MULCH	SY	2700		
0610	999-9700	WEED CONTROL FABRIC 3.5 OZ BOND	SY	3386		
SUBTOTAL (LANDSCAPING)						
TOTAL BID AMOUNT						

TOTAL BID AMOUNT (WORDS): _____

Company's Name: _____ **Date:** _____

Authorized Representative's Name (Print or Type)

Authorized Representative's Signature